

Chris LaRocque

From: Chris LaRocque
Sent: Monday, September 23, 2024 8:50 AM
To: Russell Sayre
Subject: FW: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO
Attachments: 1132191 9-11-2024.pdf

Did you respond to B&F regarding the quantities question?

Chris LaRocque
Administrator

Village of 
Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Plan Review <planreview@bfccs.org>
Sent: Wednesday, September 11, 2024 1:25 PM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: r.sayre@gotion.com
Subject: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Good Day,

We have completed the plan review for Sigma-Aldrich Inc located at 3050 Spruce Street, St Louis, MO.

The Project number 1132191.

Thank you,
Jean Michels
Administrative Assistant
B & F Construction Code Services, Inc.
2420 Vantage Drive. Elgin IL, 60124
847-428-7010 Main | 847-428-3151 Fax | constructioncodes.com

INSPECTION REQUESTS CAN BE DONE ONLINE.

Please click to schedule an inspection: Inspection Request — B&F Construction Code Services, Inc.
<<https://www.constructioncodes.com/inspections>>

Send plan review requests to: planreview@bfccs.org <<mailto:planreview@bfccs.org>>

To ensure timely receipt, please send inspection requests by 3:00pm the day prior to service**

Chris LaRocque

From: Russell Sayre <r.sayre@gotion.com>
Sent: Monday, September 23, 2024 9:06 AM
To: Chris LaRocque
Cc: Branden Brickles
Subject: RE: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Yes,

There is no storage of Lithium Hexafluorophosphate stored in the building or on the property as part of phase 1. This will become relevant in phase 2 as we begin manufacturing.

Phase 1 is only assembly, the batteries are already manufactured, tested & sealed prior to reaching our facility. The Hexafluorophosphate is an electrolyte that evaporates out of the batteries during the manufacturing process, but the chemical is not stored or kept on site as part of PH1.

We will have none stored or present on site for this phase.

Please let me know if I need to speak to anyone directly, I never received this letter and just answered these questions over the phone with a gentleman that called me from B&F. He did not ask me to issue a letter, but I'm happy to throw this email on a word doc and send to you if you need it.

Thanks,
Cole Sayre
502-229-6489



From: Chris LaRocque <clarocque@villageofmanteno.com>
Sent: Monday, September 23, 2024 9:50 AM
To: Russell Sayre <r.sayre@gotion.com>
Subject: FW: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

CAUTION: This email originated from outside of Gotion. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Did you respond to B&F regarding the quantities question?

Chris LaRocque
Administrator

Village of
Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Plan Review <planreview@bfccs.org>
Sent: Wednesday, September 11, 2024 1:25 PM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: r.sayre@gotion.com
Subject: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Good Day,

We have completed the plan review for Sigma-Aldrich Inc located at 3050 Spruce Street, St Louis, MO.

The Project number 1132191.

Thank you,
Jean Michels
Administrative Assistant
B & F Construction Code Services, Inc.
2420 Vantage Drive. Elgin IL, 60124
847-428-7010 Main | 847-428-3151 Fax | constructioncodes.com

INSPECTION REQUESTS CAN BE DONE ONLINE.

Please click to schedule an inspection: Inspection Request — B&F Construction Code Services, Inc.
<<https://www.constructioncodes.com/inspections>>

Send plan review requests to: planreview@bfccs.org <<mailto:planreview@bfccs.org>>
To ensure timely receipt, please send inspection requests by 3:00pm the day prior to service**

Chris LaRocque

From: Chris LaRocque
Sent: Monday, September 23, 2024 9:07 AM
To: Russell Sayre
Cc: Branden Brickles
Subject: RE: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

OK, thanks for the clarification. I'll reach out to B&F to see if this suffices for approval.

Chris LaRocque
Administrator

Village of 
Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Russell Sayre <r.sayre@gotion.com>
Sent: Monday, September 23, 2024 9:06 AM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: Branden Brickles <b.brickles@gotion.com>
Subject: RE: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Yes,

There is no storage of Lithium Hexafluorophosphate stored in the building or on the property as part of phase 1. This will become relevant in phase 2 as we begin manufacturing.

Phase 1 is only assembly, the batteries are already manufactured, tested & sealed prior to reaching our facility. The Hexafluorophosphate is an electrolyte that evaporates out of the batteries during the manufacturing process, but the chemical is not stored or kept on site as part of PH1.

We will have none stored or present on site for this phase.

Please let me know if I need to speak to anyone directly, I never received this letter and just answered these questions over the phone with a gentleman that called me from B&F. He did not ask me to issue a letter, but I'm happy to throw this email on a word doc and send to you if you need it.

Thanks,
Cole Sayre
502-229-6489



From: Chris LaRocque <clarocque@villageofmanteno.com>
Sent: Monday, September 23, 2024 9:50 AM
To: Russell Sayre <r.sayre@gotion.com>
Subject: FW: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

CAUTION: This email originated from outside of Gotion. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Did you respond to B&F regarding the quantities question?

Chris LaRocque
Administrator

Village of 
Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Plan Review <planreview@bfccs.org>
Sent: Wednesday, September 11, 2024 1:25 PM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: r.sayre@gotion.com
Subject: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Good Day,

We have completed the plan review for Sigma-Aldrich Inc located at 3050 Spruce Street, St Louis, MO.

The Project number 1132191.

Thank you,
Jean Michels
Administrative Assistant
B & F Construction Code Services, Inc.
2420 Vantage Drive. Elgin IL, 60124
847-428-7010 Main | 847-428-3151 Fax | constructioncodes.com

INSPECTION REQUESTS CAN BE DONE ONLINE.

Please click to schedule an inspection: Inspection Request — B&F Construction Code Services, Inc.
<<https://www.constructioncodes.com/inspections>>

Send plan review requests to: planreview@bfccs.org <<mailto:planreview@bfccs.org>>

To ensure timely receipt, please send inspection requests by 3:00pm the day prior to service**

Chris LaRocque

From: Chris LaRocque
Sent: Monday, September 23, 2024 9:51 AM
To: Plan Review
Subject: FW: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

To: Michael Paige

Per the review letter dated September 11, 2024, for Project #1132191 – See below for the explanation which was previously provided verbally by phone. Please provide the village an updated review letter if this information is adequate for compliance.

Chris LaRocque
Administrator

Village of 
Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Russell Sayre <r.sayre@gotion.com>
Sent: Monday, September 23, 2024 9:06 AM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: Branden Brickles <b.brickles@gotion.com>
Subject: RE: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Yes,

There is no storage of Lithium Hexafluorophosphate stored in the building or on the property as part of phase 1. This will become relevant in phase 2 as we begin manufacturing.

Phase 1 is only assembly, the batteries are already manufactured, tested & sealed prior to reaching our facility. The is Hexafluorophosphate is an electrolyte that evaporates out of the batteries during the manufacturing process, but the chemical is not stored or kept on site as part of PH1.

We will have none stored or present on site for this phase.

Please let me know if I need to speak to anyone directly, I never received this letter and just answered these questions over the phone with a gentleman that called me from B&F. He did not ask me to issue a letter, but I'm happy to throw this email on a word doc and send to you if you need it.

Thanks,
Cole Sayre

502-229-6489



From: Chris LaRocque <clarocque@villageofmanteno.com>
Sent: Monday, September 23, 2024 9:50 AM
To: Russell Sayre <r.sayre@gotion.com>
Subject: FW: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

CAUTION: This email originated from outside of Gotion. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Did you respond to B&F regarding the quantities question?

Chris LaRocque
Administrator

Village of

Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Plan Review <planreview@bfccs.org>
Sent: Wednesday, September 11, 2024 1:25 PM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: r.sayre@gotion.com
Subject: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Good Day,

We have completed the plan review for Sigma-Aldrich Inc located at 3050 Spruce Street, St Louis, MO.

The Project number 1132191.

Thank you,
Jean Michels
Administrative Assistant
B & F Construction Code Services, Inc.
2420 Vantage Drive. Elgin IL, 60124
847-428-7010 Main | 847-428-3151 Fax | constructioncodes.com

INSPECTION REQUESTS CAN BE DONE ONLINE.

Please click to schedule an inspection: Inspection Request — B&F Construction Code Services, Inc.
<<https://www.constructioncodes.com/inspections>>

Send plan review requests to: planreview@bfccs.org <<mailto:planreview@bfccs.org>>

To ensure timely receipt, please send inspection requests by 3:00pm the day prior to service**

Chris LaRocque

From: Plan Review <planreview@bfccs.org>
Sent: Monday, September 23, 2024 10:06 AM
To: Chris LaRocque
Subject: RE: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

This has been received and we will process.

Thank you,
Joanne Ward
Administrative Team Leader
B & F Construction Code Services, Inc.
2420 Vantage Drive. Elgin IL, 60124
847-428-7010 Main | 847-428-3151 Fax | constructioncodes.com

Please Note:

INSPECTION REQUESTS CAN BE DONE ONLINE.

Inspection Request — B&F Construction Code Services, Inc.

Send plan review requests to: planreview@bfccs.org

To ensure timely receipt, please send inspection requests by 3:00pm the day prior to service**

From: Chris LaRocque <clarocque@villageofmanteno.com>
Sent: Monday, September 23, 2024 9:51 AM
To: Plan Review <planreview@bfccs.org>
Subject: FW: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

To: Michael Paige

Per the review letter dated September 11, 2024, for Project #1132191 – See below for the explanation which was previously provided verbally by phone. Please provide the village an updated review letter if this information is adequate for compliance.

Chris LaRocque
Administrator

Village of

Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Russell Sayre <r.sayre@gotion.com>
Sent: Monday, September 23, 2024 9:06 AM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: Branden Brickles <b.brickles@gotion.com>
Subject: RE: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Yes,

There is no storage of Lithium Hexafluorophosphate stored in the building or on the property as part of phase 1. This will become relevant in phase 2 as we begin manufacturing.

Phase 1 is only assembly, the batteries are already manufactured, tested & sealed prior to reaching our facility. The is Hexafluorophosphate is an electrolyte that evaporates out of the batteries during the manufacturing process, but the chemical is not stored or kept on site as part of PH1.

We will have none stored or present on site for this phase.

Please let me know if I need to speak to anyone directly, I never received this letter and just answered these questions over the phone with a gentleman that called me from B&F. He did not ask me to issue a letter, but I'm happy to throw this email on a word doc and send to you if you need it.

Thanks,
Cole Sayre
502-229-6489



From: Chris LaRocque <clarocque@villageofmanteno.com>
Sent: Monday, September 23, 2024 9:50 AM
To: Russell Sayre <r.sayre@gotion.com>
Subject: FW: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

CAUTION: This email originated from outside of Gotion. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Did you respond to B&F regarding the quantities question?

Chris LaRocque
Administrator

Village of
Manteno
98 East Third Street
Manteno, IL 60950
815-929-4842

From: Plan Review <planreview@bfccs.org>
Sent: Wednesday, September 11, 2024 1:25 PM
To: Chris LaRocque <clarocque@villageofmanteno.com>
Cc: r.sayre@gotion.com
Subject: 1132191 - Sigma-Aldrich Inc @ 3050 Spruce Street, St Louis, MO

Good Day,

We have completed the plan review for Sigma-Aldrich Inc located at 3050 Spruce Street, St Louis, MO.

The Project number 1132191.

Thank you,
Jean Michels
Administrative Assistant
B & F Construction Code Services, Inc.
2420 Vantage Drive. Elgin IL, 60124
847-428-7010 Main | 847-428-3151 Fax | constructioncodes.com

INSPECTION REQUESTS CAN BE DONE ONLINE.

Please click to schedule an inspection: Inspection Request — B&F Construction Code Services, Inc.
<<https://www.constructioncodes.com/inspections>>

Send plan review requests to: planreview@bfccs.org <<mailto:planreview@bfccs.org>>

To ensure timely receipt, please send inspection requests by 3:00pm the day prior to service**

Chris LaRocque

From: Plan Review <planreview@bfccs.org>
Sent: Monday, September 23, 2024 2:11 PM
To: Chris LaRocque
Subject: 1132191 - Sigma-Aldrich Inc. @ 3050 Spruce Street, St Louis, MO

Good Day,

We have received the following information for Plan Review for the Sigma-Aldrich Inc. located at 3050 Spruce Street, St Louis, MO.

The Project number assigned for this submittal is 1132191.

The following documents were received for the review:
Digital Submittal.

As requested, we will perform the following reviews:
Code Study (2),

This project is scheduled to be completed on or before 9/30/2024.

Colleen Barton
Administrative Assistant

B & F Construction Code Services, Inc.
2420 Vantage Dr. Elgin, IL 60124
847-428-7010 Main | 847-428-3151 Fax | ConstructionCodes.com <<https://www.constructioncodes.com/>>

INSPECTION REQUESTS CAN BE DONE ONLINE.

Inspection Request — B&F Construction Code Services, Inc.
<<https://www.constructioncodes.com/inspections>>

Send plan review requests to: planreview@bfccs.org <<mailto:planreview@bfccs.org>>

To ensure timely receipt, please send inspection requests by 3:00pm the day prior to service**